



**BLAKELY SCHOOL NON – MOTORIZED IMPROVEMENTS
SECOND ADVERTISEMENT**

**Addendum No. 1
June 25, 2009**

Date of Addendum Issue: June 25, 2009, 2007
Sealed Bids Due: Monday, July 6, 2009, 10:30 a.m.
Bid Opening: Monday, July 6, 2009, 11:00 a.m.

NOTICE TO ALL PLAN HOLDERS

This Addendum No. 1, containing the following revisions, additions, deletions, and/or clarifications, is hereby made a part of the Plans and Contract Provisions (Contract Documents) for the above-named project. Bidders shall take this Addendum into consideration when preparing and submitting their bids.

Bidders shall acknowledge receipt and acceptance of this Addendum No. 1 in the space provided on the Proposal/Construction Contract Form. Failure to provide written acknowledgement may result in disqualification of the Bidders submittal.

Addendum No.	Page/ Drawing	Location or Description of Change
--------------	------------------	-----------------------------------

PLANS

1.001	C4	The drain pipe at the infiltration trench is the full length. The drawings show two segments which is not correct.
1.002	C4	The West end of the drain pipe at the infiltration trench is shown in the drawings to be at STA26+95. This is not correct. The correct location is STA29+95.

End Addendum No. 1

Signed:

KCH



Robert Earl, P.E. – City Engineer